

PRODUCT DESCRIPTION**Banking:**

- LDPE.

Colour:

- red, blue, yellow, orange.

Thickness:

- from 0.08 mm to 0.5 mm.

Width:

- 200 mm,
- other dimensions upon request.

Length:

- 100 m

Product meets the applicable restrictions of RoHS Directive and Reach regulations.



ANTICOR Sp. z o.o. holds ISO 9001.

252

PE-Foil marking tape for routs of steel pipelines and underground electrical power cables **with the inscription: GAS, WATER SUPPLY, SEWAGE SYSTEM, FIBER OPTIC CABLE.**

APPLICATION

- For routs of steel pipelines and underground electric and power cables.

FEATURES AND ADVENTAGES

- Marking tapes with thickness $\geq 0,3$ mm comply with standard SEP-E-04.

USAGE

- Marking tape should be placed at least 30 cm over electric cable or pipe line in the ground.

STORAGE

- To ensure the maximum product performance store product in a dry area, away from direct sunlight.
- Protect the products in original packaging against mechanical damage.
- The recommended storage temperature: $-5 \div 40^{\circ}\text{C}$.