



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DG-5180DM0483**  
Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	ANTICOR Sp. z o.o. ul. Wygoda 28, PL-32-020 Wieliczka
<b>Distributor</b> <i>Vertreiber</i>	ANTICOR Sp. z o.o. ul. Wygoda 28, PL-32-020 Wieliczka
<b>Product Category</b> <i>Produktart</i>	greasing and sealing materials: Protection tape against corrosion (5180)
<b>Product Description</b> <i>Produktbezeichnung</i>	Petrolatum tape
<b>Model</b> <i>Modell</i>	ANTICOR Plast 701-40 / 732-08 / 745
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: 21-00346 from 17.08.2021 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999)

**Date of Expiry / File No.** 17.08.2026 / 21-0608-GNE  
**Ablaufdatum / Aktenzeichen**

14.10.2021 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com



<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
ANTICOR Plast 701-40 / 732-08 / 745	stress-class: A permanent operating temperature: ...+30 °C designation according to standard: Coating DIN EN 12068-A30	

**Hints of Utilization / Remarks*****Verwendungshinweise / Bemerkungen***

Application: cold applied corrosion protection tape; inner layer ANTICOR Plast 701-40 wrapped twice with 2 x 50% overlap (4 layers) and outer layer ANTICOR Plast 732-08 wrapped once with 1 x 50% overlap (2 layers), optionally with Anticor Plast 745 (for smoothing the surface)